

scheme long name	scheme type	indicator title	value	units	comments
Mount Morgan Water Supply Scheme	Potable water scheme	Number water treatment plants: providing full treatment		1 Count	
Mount Morgan Water Supply Scheme	Potable water scheme	Length water mains		72.6 km	
Mount Morgan Water Supply Scheme	Potable water scheme	Capacity of water treatment plants		2.6 ML/day	
Mount Morgan Water Supply Scheme	Potable water scheme	Total potable water storage volume		5 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume water lost: potable water		43 ML	Aparent losses
Mount Morgan Water Supply Scheme	Potable water scheme	Water main breaks per 100 km water main		2.8 per 100 km water main	
Mount Morgan Water Supply Scheme	Potable water scheme	Water service complaints per 1000 connections		15.4 per 1000 connections	
Mount Morgan Water Supply Scheme	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections		0.7 per 1000 connections	
Mount Morgan Water Supply Scheme	Potable water scheme	Water and sewerage complaints (all) per 1000 connections		16.1 per 1000 connections	
Mount Morgan Water Supply Scheme	Potable water scheme	Average frequency unplanned interruptions: water		16.1 per 1000 connections	
Mount Morgan Water Supply Scheme	Potable water scheme	Connected residential properties: water		1.399 000s	
Mount Morgan Water Supply Scheme	Potable water scheme	Connected non-residential properties: water		0.09 000s	
Mount Morgan Water Supply Scheme	Potable water scheme	Percent CSS response target met: water incidents		100 %	
Mount Morgan Water Supply Scheme	Potable water scheme	Water quality complaints per 1000 connections		0 per 1000 connections	
Mount Morgan Water Supply Scheme	Potable water scheme	Fixed charge: water value		506 \$/annum	
Mount Morgan Water Supply Scheme	Potable water scheme	Fixed charge: water description	per meter or per lot as appropriate		
Mount Morgan Water Supply Scheme	Potable water scheme	Volume water sourced: surface water		1 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume water sourced: groundwater		0 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Maximum daily demand		1 ML/day	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume all water imported: internal and external		256.2 ML	Potable Water imported from RWSS
Mount Morgan Water Supply Scheme	Potable water scheme	Volume all water exported: internal and external		0 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume potable water produced at a water treatment plant		0 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume potable water supplied: residential		187.2 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume potable water supplied: non-residential		26 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume water sourced: desalination marine water		0 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Volume water sourced: all		257.2 ML	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: PWCM		0 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: Level 1		0 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: Level 2		0 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: Level 3		0 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: Level 4		0 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Water restriction duration: Level 5		365 days	
Mount Morgan Water Supply Scheme	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Mount Morgan Water Supply Scheme	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Mount Morgan Water Supply Scheme	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Last occured in 2017, population has been very stable.
Mount Morgan Water Supply Scheme	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
Mount Morgan Water Supply Scheme	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
Mount Morgan Water Supply Scheme	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		3 1,2,3,4,5,6	
Mount Morgan Water Supply Scheme	Potable water scheme	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
Mount Morgan Water Supply Scheme	Potable water scheme	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
Mount Morgan Water Supply Scheme	Potable water scheme	Available contingency supplies	yes	yes/no	Supply by water tanker
Rockhampton Water Supply Scheme	Potable water scheme	Number water treatment plants: providing full treatment		1 Count	
Rockhampton Water Supply Scheme	Potable water scheme	Length water mains		790 km	
Rockhampton Water Supply Scheme	Potable water scheme	Capacity of water treatment plants		120 ML/day	
Rockhampton Water Supply Scheme	Potable water scheme	Total potable water storage volume		103 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume water lost: potable water		2902 ML	Aparent losses
Rockhampton Water Supply Scheme	Potable water scheme	Water main breaks per 100 km water main		6.6 per 100 km water main	
Rockhampton Water Supply Scheme	Potable water scheme	Water service complaints per 1000 connections		25.1 per 1000 connections	
Rockhampton Water Supply Scheme	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections		0.3 per 1000 connections	
Rockhampton Water Supply Scheme	Potable water scheme	Water and sewerage complaints (all) per 1000 connections		27 per 1000 connections	
Rockhampton Water Supply Scheme	Potable water scheme	Average frequency unplanned interruptions: water		47.7 per 1000 connections	
Rockhampton Water Supply Scheme	Potable water scheme	Connected residential properties: water		28.296 000s	
Rockhampton Water Supply Scheme	Potable water scheme	Connected non-residential properties: water		3.265 000s	
Rockhampton Water Supply Scheme	Potable water scheme	Percent CSS response target met: water incidents		100 %	
Rockhampton Water Supply Scheme	Potable water scheme	Water quality complaints per 1000 connections		1.6 per 1000 connections	
Rockhampton Water Supply Scheme	Potable water scheme	Fixed charge: water value		462 \$/annum	
Rockhampton Water Supply Scheme	Potable water scheme	Fixed charge: water description	per meter or per lot as appropriate		
Rockhampton Water Supply Scheme	Potable water scheme	Volume water sourced: surface water		20677.7 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume water sourced: groundwater		0 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Maximum daily demand		77.3 ML/day	
Rockhampton Water Supply Scheme	Potable water scheme	Volume all water imported: internal and external		0 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume all water exported: internal and external		3077.1 ML	Potable water, 2820.9
Rockhampton Water Supply Scheme	Potable water scheme	Volume potable water produced at a water treatment plant		19091.3 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume potable water supplied: residential		7674.6 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume potable water supplied: non-residential		4604.5 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume water sourced: desalination marine water		0 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Volume water sourced: all		20677.7 ML	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: PWCM	NR	days	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: Level 1		0 days	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: Level 2		0 days	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: Level 3		0 days	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: Level 4		0 days	
Rockhampton Water Supply Scheme	Potable water scheme	Water restriction duration: Level 5		0 days	
Rockhampton Water Supply Scheme	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Rockhampton Water Supply Scheme	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Rockhampton Water Supply Scheme	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Last occured in 2016, population appear to be following predicted forecasts close
Rockhampton Water Supply Scheme	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	

Rockhampton Water Supply Scheme	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
Rockhampton Water Supply Scheme	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		5 1,2,3,4,5,6	
Rockhampton Water Supply Scheme	Potable water scheme	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
Rockhampton Water Supply Scheme	Potable water scheme	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
Rockhampton Water Supply Scheme	Potable water scheme	Available contingency supplies	yes	yes/no	Access to water below
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Length water mains	NR	km	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water main breaks per 100 km water main	NR	per 100 km water main	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water service complaints per 1000 connections		0 per 1000 connections	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water and sewerage complaints (all) per 1000 connections		0 per 1000 connections	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Connected residential properties: water		0.159 000s	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Connected non-residential properties: water		0.141 000s	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Percent CSS response target met: water incidents	NR	%	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water quality complaints per 1000 connections		0 per 1000 connections	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Fixed charge: water value		0 \$/annum	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Fixed charge: water description	NR	Text	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume water sourced: surface water		2511.2 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume water sourced: groundwater		0 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Maximum daily demand	NR	ML/day	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume all water imported: internal and external		0 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume all water exported: internal and external		0 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume water sourced: desalination marine water		0 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume water sourced: all		2511.2 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume raw-PT water supplied: residential		460.9 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Volume raw-PT water supplied: non-residential		2050.3 ML	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: PWCM	NR	days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: Level 1		0 days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: Level 2		0 days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: Level 3		0 days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: Level 4		0 days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Water restriction duration: Level 5		0 days	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	Is a medium priority irrigation scheme
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	Is a medium priority irrigation scheme
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Is a medium priority
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Is a medium priority irrigation scheme
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Months water supply remaining as at 30 June (KPI level)		5 1,2,3,4,5,6	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
Fitzroy Barrage Water Supply Scheme	Raw-Partially treated water scheme	Available contingency supplies	no	yes/no	Is a medium priority irrigation scheme
Gracemere Recycled Water Scheme	Recycled water scheme	Length water mains		14.6 km	
Gracemere Recycled Water Scheme	Recycled water scheme	Water main breaks per 100 km water main		0 per 100 km water main	
Gracemere Recycled Water Scheme	Recycled water scheme	Water service complaints per 1000 connections		500 per 1000 connections	
Gracemere Recycled Water Scheme	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections	
Gracemere Recycled Water Scheme	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections		500 per 1000 connections	
Gracemere Recycled Water Scheme	Recycled water scheme	Connected residential properties: water		0 000s	
Gracemere Recycled Water Scheme	Recycled water scheme	Connected non-residential properties: water		0.002 000s	
Gracemere Recycled Water Scheme	Recycled water scheme	Water quality complaints per 1000 connections		0 per 1000 connections	
Gracemere Recycled Water Scheme	Recycled water scheme	Fixed charge: water value		0 \$/annum	
Gracemere Recycled Water Scheme	Recycled water scheme	Fixed charge: water description	NR	Text	
Gracemere Recycled Water Scheme	Recycled water scheme	Volume all water imported: internal and external	NR	ML	
Gracemere Recycled Water Scheme	Recycled water scheme	Volume all water exported: internal and external	NR	ML	
Gracemere Recycled Water Scheme	Recycled water scheme	Volume recycled sewage supplied: all		755.8 ML	
Gracemere Recycled Water Scheme	Recycled water scheme	Volume water sourced: all		755.8 ML	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Length water mains		2.6 km	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Water main breaks per 100 km water main		0 per 100 km water main	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Water service complaints per 1000 connections		400 per 1000 connections	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections		400 per 1000 connections	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Connected residential properties: water		0 000s	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Connected non-residential properties: water		0.005 000s	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Water quality complaints per 1000 connections		0 per 1000 connections	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Fixed charge: water value		0 \$/annum	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Fixed charge: water description	NR	Text	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Volume all water imported: internal and external	NR	ML	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Volume all water exported: internal and external	NR	ML	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Volume recycled sewage supplied: all		61.7 ML	
Mount Morgan Recycled Water Scheme	Recycled water scheme	Volume water sourced: all		61.7 ML	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Length water mains		0.1 km	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Water main breaks per 100 km water main		0 per 100 km water main	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Water service complaints per 1000 connections		0 per 1000 connections	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections		0 per 1000 connections	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Connected residential properties: water		0 000s	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Connected non-residential properties: water		0 000s	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Water quality complaints per 1000 connections		0 per 1000 connections	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Fixed charge: water value		0 \$/annum	
North Rockhampton Recycled Water Scheme	Recycled water scheme	Fixed charge: water description	NR	Text	

North Rockhampton Recycled Water Scheme	Recycled water scheme	Volume all water imported: internal and external	NR	ML
North Rockhampton Recycled Water Scheme	Recycled water scheme	Volume all water exported: internal and external	NR	ML
North Rockhampton Recycled Water Scheme	Recycled water scheme	Volume recycled sewage supplied: all		0 ML
North Rockhampton Recycled Water Scheme	Recycled water scheme	Volume water sourced: all		0 ML
South Rockhampton Recycled Water Scheme	Recycled water scheme	Length water mains		0.7 km
South Rockhampton Recycled Water Scheme	Recycled water scheme	Water main breaks per 100 km water main		0 per 100 km water main
South Rockhampton Recycled Water Scheme	Recycled water scheme	Water service complaints per 1000 connections		0 per 1000 connections
South Rockhampton Recycled Water Scheme	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
South Rockhampton Recycled Water Scheme	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections		0 per 1000 connections
South Rockhampton Recycled Water Scheme	Recycled water scheme	Connected residential properties: water		0 000s
South Rockhampton Recycled Water Scheme	Recycled water scheme	Connected non-residential properties: water		0 000s
South Rockhampton Recycled Water Scheme	Recycled water scheme	Water quality complaints per 1000 connections		0 per 1000 connections
South Rockhampton Recycled Water Scheme	Recycled water scheme	Fixed charge: water value		0 \$/annum
South Rockhampton Recycled Water Scheme	Recycled water scheme	Fixed charge: water description	NR	Text
South Rockhampton Recycled Water Scheme	Recycled water scheme	Volume all water imported: internal and external	NR	ML
South Rockhampton Recycled Water Scheme	Recycled water scheme	Volume all water exported: internal and external	NR	ML
South Rockhampton Recycled Water Scheme	Recycled water scheme	Volume recycled sewage supplied: all		0 ML
South Rockhampton Recycled Water Scheme	Recycled water scheme	Volume water sourced: all		0 ML
Gracemere Sewerage Scheme	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main		10.8 per 100 km sewer mains
Gracemere Sewerage Scheme	Sewerage scheme	Number sewage treatment plants		1 Count
Gracemere Sewerage Scheme	Sewerage scheme	Length sewerage mains and channels		120.3 km
Gracemere Sewerage Scheme	Sewerage scheme	Sewerage service complaints per 1000 connections		13.6 per 1000 connections
Gracemere Sewerage Scheme	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
Gracemere Sewerage Scheme	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections		13.6 per 1000 connections
Gracemere Sewerage Scheme	Sewerage scheme	Connected residential properties: sewerage		3.935 000s
Gracemere Sewerage Scheme	Sewerage scheme	Percent CSS response target met: sewerage incidents		83.8 %
Gracemere Sewerage Scheme	Sewerage scheme	Connected non-residential properties: sewerage		0.11 000s
Gracemere Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage value		957 \$/annum
Gracemere Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage description	Each residence (regardless of number of pedestals)	
Mount Morgan Sewerage Scheme	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main		0 per 100 km sewer mains
Mount Morgan Sewerage Scheme	Sewerage scheme	Number sewage treatment plants		1 Count
Mount Morgan Sewerage Scheme	Sewerage scheme	Length sewerage mains and channels		14.9 km
Mount Morgan Sewerage Scheme	Sewerage scheme	Sewerage service complaints per 1000 connections		2.8 per 1000 connections
Mount Morgan Sewerage Scheme	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
Mount Morgan Sewerage Scheme	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections		2.8 per 1000 connections
Mount Morgan Sewerage Scheme	Sewerage scheme	Connected residential properties: sewerage		0.312 000s
Mount Morgan Sewerage Scheme	Sewerage scheme	Percent CSS response target met: sewerage incidents		100 %
Mount Morgan Sewerage Scheme	Sewerage scheme	Connected non-residential properties: sewerage		0.051 000s
Mount Morgan Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage value		901 \$/annum
Mount Morgan Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage description	Each residence (regardless of number of pedestals)	
North Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main		16.4 per 100 km sewer mains
North Rockhampton Sewerage Scheme	Sewerage scheme	Number sewage treatment plants		1 Count
North Rockhampton Sewerage Scheme	Sewerage scheme	Length sewerage mains and channels		438.4 km
North Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage service complaints per 1000 connections		17.4 per 1000 connections
North Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
North Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections		17.4 per 1000 connections
North Rockhampton Sewerage Scheme	Sewerage scheme	Connected residential properties: sewerage		16.144 000s
North Rockhampton Sewerage Scheme	Sewerage scheme	Percent CSS response target met: sewerage incidents		83.8 %
North Rockhampton Sewerage Scheme	Sewerage scheme	Connected non-residential properties: sewerage		1.239 000s
North Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage value		746 \$/annum
North Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage description	Each residence (regardless of number of pedestals)	
South Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main		21.1 per 100 km sewer mains
South Rockhampton Sewerage Scheme	Sewerage scheme	Number sewage treatment plants		1 Count
South Rockhampton Sewerage Scheme	Sewerage scheme	Length sewerage mains and channels		170.6 km
South Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage service complaints per 1000 connections		17.5 per 1000 connections
South Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
South Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections		17.5 per 1000 connections
South Rockhampton Sewerage Scheme	Sewerage scheme	Connected residential properties: sewerage		8.192 000s
South Rockhampton Sewerage Scheme	Sewerage scheme	Percent CSS response target met: sewerage incidents		83.8 %
South Rockhampton Sewerage Scheme	Sewerage scheme	Connected non-residential properties: sewerage		0.629 000s
South Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage value		746 \$/annum
South Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage description	Each residence (regardless of number of pedestals)	
West Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main		0 per 100 km sewer mains
West Rockhampton Sewerage Scheme	Sewerage scheme	Number sewage treatment plants		0 Count
West Rockhampton Sewerage Scheme	Sewerage scheme	Length sewerage mains and channels		0 km
West Rockhampton Sewerage Scheme	Sewerage scheme	Sewerage service complaints per 1000 connections		0 per 1000 connections
West Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections
West Rockhampton Sewerage Scheme	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections		0 per 1000 connections
West Rockhampton Sewerage Scheme	Sewerage scheme	Connected residential properties: sewerage		0 000s
West Rockhampton Sewerage Scheme	Sewerage scheme	Percent CSS response target met: sewerage incidents		100 %
West Rockhampton Sewerage Scheme	Sewerage scheme	Connected non-residential properties: sewerage		0 000s
West Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage value		746 \$/annum
West Rockhampton Sewerage Scheme	Sewerage scheme	Fixed charge: sewerage description	Each residence (regardless of number of pedestals)	
Rockhampton Regional Council WSP-wide	WSP	Number water treatment plants: providing full treatment		2 Count
Rockhampton Regional Council WSP-wide	WSP	Length water mains		880.6 km
Rockhampton Regional Council WSP-wide	WSP	Sewerage mains breaks/chokes per 100 km sewer main		16.3 per 100 km sewer mains
Rockhampton Regional Council WSP-wide	WSP	Number sewage treatment plants		4 Count
Rockhampton Regional Council WSP-wide	WSP	Capacity of water treatment plants		122.6 ML/day

Rockhampton Regional Council WSP-wide	WSP	Total potable water storage volume		108 ML	
Rockhampton Regional Council WSP-wide	WSP	Length sewerage mains and channels		744.2 km	
Rockhampton Regional Council WSP-wide	WSP	Volume water lost: potable water		2945 ML	
Rockhampton Regional Council WSP-wide	WSP	Water main breaks per 100 km water main		6.1 per 100 km water main	
Rockhampton Regional Council WSP-wide	WSP	Water service complaints per 1000 connections		24.5 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Sewerage service complaints per 1000 connections		16.8 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Water and sewerage billing and account complaints per 1000 connections		0.3 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Water and sewerage complaints (all) per 1000 connections		41.7 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Average frequency unplanned interruptions: water		46.3 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Connected residential properties: water		29.854 000s	
Rockhampton Regional Council WSP-wide	WSP	Connected non-residential properties: water		3.496 000s	
Rockhampton Regional Council WSP-wide	WSP	Connected residential properties: sewerage		28.583 000s	
Rockhampton Regional Council WSP-wide	WSP	Percent CSS response target met: sewerage incidents		83.9 %	
Rockhampton Regional Council WSP-wide	WSP	Percent CSS response target met: water incidents		100 %	
Rockhampton Regional Council WSP-wide	WSP	Connected non-residential properties: sewerage		2.029 000s	
Rockhampton Regional Council WSP-wide	WSP	Water quality complaints per 1000 connections		1.5 per 1000 connections	
Rockhampton Regional Council WSP-wide	WSP	Revenue: all (NPR) water		50093.845 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Nominal written down replacement cost: fixed sewerage assets		231564.976 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: operating water per connection		619.31 \$/connection	
Rockhampton Regional Council WSP-wide	WSP	Costs: operating sewerage per connection		505.7 \$/connection	
Rockhampton Regional Council WSP-wide	WSP	Capital expenditure: water supply		15295.159 \$,000	
					Major works - NRSTP train duplication
Rockhampton Regional Council WSP-wide	WSP	Capital expenditure: sewerage		30094.49 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Revenue: all (NPR) sewerage		34713.82 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Capital works grants: water		0 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Capital works grants: sewerage		3464 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: operating water (NPR)		20654.1 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: operating sewerage		15480.495 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: any other water		10801.215 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: any other sewerage		4972.63 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Current replacement costs: fixed water assets		735606.421 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Current replacement costs: fixed sewerage assets		390778.66 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: maintenance water		10877.928 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Costs: maintenance sewerage		11615.818 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Current cost depreciation: water		10648.127 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Current cost depreciation: sewerage		4870.572 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Previous 5 year average annual renewals expenditure: water		6795.788 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Previous 5 year average annual renewals expenditure: sewerage		3197.387 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Forecast 5 year average annual renewals expenditure: water		16300.648 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Forecast 5 year average annual renewals expenditure: sewerage		17322.188 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Nominal written down replacement cost: fixed water assets		426313.868 \$,000	
Rockhampton Regional Council WSP-wide	WSP	Fixed charge: water value		462 \$/annum	
Rockhampton Regional Council WSP-wide	WSP	Fixed charge: sewerage value		746 \$/annum	
Rockhampton Regional Council WSP-wide	WSP	Fixed charge: sewerage description			Each residence (regardless of number of pedestals)
Rockhampton Regional Council WSP-wide	WSP	Annual bill based on 200kL/a: water+sewerage		1396 \$	
Rockhampton Regional Council WSP-wide	WSP	Typical residential bill: water+sewerage		1462.74 \$	
Rockhampton Regional Council WSP-wide	WSP	Fixed charge: water description			per meter or per lot as appropriate
Rockhampton Regional Council WSP-wide	WSP	Volume water sourced: surface water		23189.9 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume water sourced: groundwater		0 ML	
Rockhampton Regional Council WSP-wide	WSP	Maximum daily demand		78.3 ML/day	
Rockhampton Regional Council WSP-wide	WSP	Volume all water imported: internal and external		256.2 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume all water exported: internal and external		3077.1 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume potable water produced at a water treatment plant		19091.3 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume recycled sewage supplied: all		817.5 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume potable water supplied: residential		7861.8 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume potable water supplied: non-residential		4630.5 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume water sourced: desalination marine water		0 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume water sourced: all		24263.6 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume raw-PT water supplied: residential		460.9 ML	
Rockhampton Regional Council WSP-wide	WSP	Volume raw-PT water supplied: non-residential		2050.3 ML	
Rockhampton Regional Council WSP-wide	WSP	Total full-time equivalent water+sewerage employees		110 FTEs	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: PWCM		0 days	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: Level 1		0 days	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: Level 2		0 days	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: Level 3		0 days	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: Level 4		0 days	
Rockhampton Regional Council WSP-wide	WSP	Water restriction duration: Level 5		365 days	
Rockhampton Regional Council WSP-wide	WSP	Has asset management planning been undertaken in the last 10 yrs?	yes		yes/no
Rockhampton Regional Council WSP-wide	WSP	Has drought management planning been undertaken in the last 10 yrs?	yes		yes/no
Rockhampton Regional Council WSP-wide	WSP	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes		yes/no
Rockhampton Regional Council WSP-wide	WSP	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes		yes/no
Rockhampton Regional Council WSP-wide	WSP	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes		yes/no
Rockhampton Regional Council WSP-wide	WSP	Months water supply remaining as at 30 June (KPI level)		5 1,2,3,4,5,6	
Rockhampton Regional Council WSP-wide	WSP	Confidence water demand will be met: next 18 mths	high		high,fair,unsure,low,very low
Rockhampton Regional Council WSP-wide	WSP	Confidence water demand will be met: next 5 yrs	high		high,fair,unsure,low,very low
Rockhampton Regional Council WSP-wide	WSP	Available contingency supplies	NR		yes/no

